

FIRE SAFETY CERTIFICATE

No.

Dated: 2/11/22

Certified that the Sri Vani Vidyalaya at Ward No: 47, Mangasamudram, Santhapet, Chittoor Town, Chittoor District, A.P. comprised of basement and 1st Floor occupied by Sri Vani Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 25-10-2022 in the presence of R. Ramana (Correspondent) and that the building/ premises is fit for occupancy upto classes I to X With effect from 02-11-2022 for a period of 5 years in accordance with rule and subject to compliance of specific conditions as appended:-

1. Fixed and first-aid fire fighting equipment, alarms etc. shall be tested and maintained regularly as per applicable standard and fire drills conducted quarterly for first two years and thereafter half year.
2. All the escape / exit routes shall not be kept locked/blocked or encroached.
3. No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
4. Any loss of life or property due to non-functioning of fire safety measures and other installations shall be responsibility of the management.


Issued on 10/11/2022 at CHITTOOR)

Signature with Seal:

Name :

Designation :

Name & Address of Department/ Office:


 (M. Karunakar)
 Asst. District Fire Officer,
 A.P.S.D.R & Fire Services Dept.,
 Chittoor Fire Station.